

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 14

Dated- 24/01/2025

It is certified that an inspection team headed by JALKAL VIBHAG NAGAR NIGAM PRAYAGRAJ (Name of Officers with designation) from SHIVAM MISHRA (EE) PHED

inspected the S.P. CONVENT SCHOOL BEGUM BAZAR BAMRAULI PRAYAGRAJ (Name & Address of the school) on 18.01.25 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. 34 dated 23.01.25 of

Jalkal Vibhag (PHED Lab) certified that the S.P. CONVENT SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus as

per norms prescribed by the Central/ State/ U.T. Govt.)

This certificate is valid till 08.06.25

इपिटोसी इपिवन्दा (मुठ)

जलकल विभाग

Signature with Seal: नगर निगम-प्रयागराज

Name : Mr. Shivam Mishra

Designation : Executive Engineer


Name & Address of the Office / Department :


To

S.P. CONVENT SCHOOL

BEGUM BAZAR BAMRAULI PRAYAGRAJ

(Name & Address of the Institution)


Principal
S. P. Convent School
Begum Bazar Bamrauli
Prayagraj


Manager
S. P. Convent School
Begum Bazar Bamrauli
Prayagraj



जलकल विभाग-नगर निगम प्रयागराज
सं. ०१/२०२५ मु.ज.क.वि.
दि. २४/०१/२५

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2025-01/04

Date: 24.01.2025

DRINKING WATER ANALYSIS REPORT

1	Name & Address	S.P. CONVENT SCHOOL BEGAM BAZAR, BAMRAULI, TAHSIL SADAR, DIST. PRAYAGRAJ
2	Sample Collected by	By Party
3	Nature of Sample	Drinking Water
4	Date of Sample Collection	18.01.2025
5	Date of Sample Receiving	18.01.2025
6	Date of Analysis Completed	23.01.2025

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	-
3.	Temperature	°C	18.6	-	-
4.	Turbidity	NTU	0.96	5	10
5.	Conductivity at 25°C	µmho/cm	803.0	-	-
CHEMICAL PARAMETERS					
6.	pH	-	6.7	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	NIL	-	-
8.	Dissolved Solids	mg/L	386.0	500	2000
9.	Total Solids	mg/L	386.0	-	-
10.	Total Alkalinity (as CaCO ₃)	mg/L	194.0	200	600
11.	Total Hardness (as CaCO ₃)	mg/L	318.0	200	600
12.	Chlorides (as Cl)	mg/L	113.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	0.1	1.0	1.5
14.	Nitrate (as NO ₃)	mg/L	1.9	45.0	100.0
15.	Iron (Fe)	mg/L	0.3	0.3	1.0
BACTERIOLOGICAL PARAMETERS					
16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

*Note: The water is suitable for drinking purposes-

Analyst

(Laboratory In-charge)

JE(HQ)

अधिसूचक अधिकारी (मु.ज.क.वि.)
जलकल विभाग
नगर निगम प्रयागराज
E.E(HQ)

Note:

- The above results are related only to the test performed on the sample.
- This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our permission.
- Sample will be destroyed in the after fifteen days from the date of reporting.

S. P. Convent School
Begum Bazar Bamrauli

Sanjeev Kishore
Manager
S. P. Convent School
Begum Bazar Bamrauli
Prayagraj